



Cummins Energy Saving

Group Number 2

Daniel Baker, Warren Bell, Daniel Carnrike,
Kyle Fields, Marvin Fonseca

Cummins Advisor: Dr. Roger England, Dr. Michael Hays

Faculty Advisor: Dr. Juan Ordonez

Instructors: Dr. Shih, Dr. Gupta, Dr. Helzer


Group 2

Slide 1 of 20



Warren Bell, Kyle Fields

Cummins Energy Saving



Overview



■ Updated Design Analysis:

- Chillers
- Insulation
- Engine Testing
 - Mechanical and Thermodynamic Power

■ Indiana Trip

■ Additional Ideas

■ Schedule

■ Summary and Future Work



Need Statement



- **“Cummins needs to reduce their energy usage in order to save money and reduce their environmental impact.”**

Goal Statement

- **The goal of the project is to, “Review current Cummins Technical Center (CTC) electrical usage and devise a plan to decrease it by 10%.”**



Primary Energy Consumption: the Energy used in the subsystem converted to primary energy in MMBTU		Ability to Influence: the level of opportunities for reductions in energy use and / or GHG emissions for that subsystem	
9	Greater than 30% of site total	9	High - Opportunities for improving efficiency and consumption will substantially decrease GHG
3	Greater than 5% but less than 30% of site total	3	Medium - Opportunities for improving efficiency and consumption may decrease GHG
1	Less than 5% of site total	1	Low - Opportunities for improving efficiency and consumption will have little or no decrease on GHG
Energy Cost: the cost of the energy in the subsystem in local currency		Ability to Measure: the level of availability of accurate, reliable data	
9	Greater than \$1 million	9	High - Metered data available
3	Greater than \$100,000 but less than \$1 million	3	Medium - Some metered data available for calculating subsystem use
1	Less than \$100,000	1	Low - No metered data available

Revision date: 8/18/2014		Significance threshold: 220						
Rating of Importance to EnMS		10	5	10	5	10	10	Total
Significance Category	Important Energy Users Energy subsystem / function	Primary Energy Consumption (MMBTU)	Cost (Currency)	Greenhouse Gases (MTCO2)	Ability to Influence	Ability to Measure	Regulatory Requirements	
1	Engine Testing (Diesel)	9	9	9	9	3	9	390
2	Facilities boilers (NG)	3	1	3	3	3	3	140
3	Test Cell Fans/Pumps (Electricity)	3	3	3	9	9	1	220
4	Test Cell, include Dynos (Electricity)	3	3	3	3	9	1	190
5	CVS Chillers & Chilled Water (Electricity)	3	3	3	9	9	1	220
6	Process water (Electricity)	3	3	3	3	9	3	210
7	Engine testing (NG)	1	1	1	3	3	9	160
8	Miscellaneous (Electricity)	1	3	1	0	9	0	125
9	Office (Electricity)	1	3	1	1	9	1	140
10	Compressors (Electricity)	1	3	1	1	9	1	140
11	Hybrid Test Cell, Cold Cell, Altitude Test Cell (Electricity)	1	3	1	1	9	1	140
12	Applied Lab (Electricity)	1	3	1	1	9	1	140
13	HTG Pump, Air Handlers-main aisle, Emergency Generator (Electricity)	1	3	1	3	9	1	150
14	Waste Heat Recovery Cells (NG)	1	1	1	1	1	3	70
15	Lighting (Electricity)	1	1	1	1	9	1	130
16	Walesboro Noise Facility (Electricity)	1	1	1	1	3	1	70

Chillers

Table 1 – Annual Power Consumption

Annual Power Consumption(kWh/yr)	VARs	VCRS
Refrigerant Pump	13,140	N/A
Solution Pump	61,320	N/A
Compressor Power	N/A	2,938,980
Chilled Water Pump	324,120	324,120
Cooling Tower Fan	131,400	87,600
LT Hot Water Pump	43,800	N/A
HT Hot Water Pump	43,800	N/A
Cooling Water Pump	324,120	262,800
Total Annual Power Consumption	941,700	3,613,500

VARs: Variable Absorption Refrigeration System
 VCRS: Vapor Compression Refrigeration System




Figure 1. Absorption Cycle



Chillers



Table 2 – Annual Cost Comparison

Table 3 – Initial Cost Comparison

Annual Operating Costs (USD)			Initial Cost (USD)		
	VARs	VCRs		VARs	VCRs
Refrigerant Pump	\$ 1,097.19	N/A	Machine Cost	\$ 278,478	\$ 112,041
Solution Pump	\$ 5,120.22	N/A	Cooling Tower	\$ 22,826	\$ 19,565
Compressor Power	N/A	\$ 245,404.83	Cooling Water Pump	\$ 5,435	\$ 4,348
Chilled Water Pump	\$ 27,064.02	\$ 27,064.02	Chilled Water Pump	\$ 3,913	\$ 3,913
Cooling Tower Fan	\$ 10,971.90	\$ 7,314.60	LT Hot Water Pump	\$ 1,848	N/A
LT Hot Water Pump	\$ 3,657.30	N/A	HT Hot Water Pump	\$ 1,848	N/A
HT Hot Water Pump	\$ 3,657.30	N/A			
Cooling Water Pump	\$ 27,064.02	\$ 21,943.80			
Total Annual Operating Cost	\$ 78,631.95	\$ 301,727.25	Total Initial Cost	\$ 314,348	\$ 139,868




Chillers



Total Cost of VARS v. VCRS Over 7 Year Period

VARS: Variable Absorption Refrigeration System
VCRS: Vapor Compression Refrigeration System



Insulation



Table 4 – Material Cost Comparison

Material	Cost (per ft^2)	Total Material Cost	Total Savings per year
Fiber Glass	0.42	\$9,606.66	\$18,331.76
Mineral Wool	0.625	\$14,295.62	\$18,352.97
Cellulose	1.25	\$28,591.25	\$18,448.09
Plastic Fiber	1.5	\$34,309.50	\$18,596.58
Closed Cell Foam	2.2	\$50,320.60	\$18,955.43
Closed Cell Foam modified	2.3	\$52,607.90	\$19,068.17

Table 5 – Material Properties

Material	Thermal Resistance	Types	Green	Fire Resistant
Fiber Glass	2.2 to 2.7	High, Medium, Low Density	20% to 30% Recycled	Yes
Mineral Wool	3.7	Blanket and loose fill	75% post-industrial recycled	Yes
Cellulose	3.2 to 3.8	loose fill or spray	82% to 85% recycled	No
Plastic Fiber	3.8 to 4.3	High, Low Density	----	Yes
Closed Cell Foam	5.6 to 8	Spray, Foam board	----	No
Closed Cell Foam modified	9	Foil	----	Yes



Engine Testing – Dynamometers



88 main Test Cells with 8 auxiliary Test Cells.

Cummins ISX15 600 used for analysis.

Table 6 – Dynamometers Properties

Variable	Value
Test Power	268.2 kW
Power Generation	7,878,643 kWh
Power Lost	1,390,348 kWh
Annual Savings	\$5,866,437,727
Annual Savings Lost (inefficiency)	\$1,035,253,716



Engine Testing – Exhaust gasses



88 main Test Cells with 8 auxiliary Test Cells

Cummins ISX15 600 used for analysis

$$Q = n * m_{\text{dot_exhaust}} * C_v (T_{\text{out}} - T_{\text{amb.}})$$

Pollutants

Table 7 – Exhaust Properties

Fuel Consumption	11.67 Gallons / Hour
Mass Flow Fuel In	10.21 g/s
Mass Flow In Air	10.58 g/s
Mass Flow In Total	20.79 g/s
Mass Flow Refuel	1.021 g/s
Mass Flow Exhaust	19.77 g/s
Specific Heat Fuel	1.832 kJ / kg*K
Heat Generated	354.1 kW
Heat Available to Convert	318.7 kW
Heat Available	1,147,294 kWh



Engine Testing – Noble Energy Conversion



Table 8 – Energy Conversion Systems Comparison

	Theoretical eff.	Actual eff.	Initial cost	Annual maintenance cost
Thermionic Generator	40%	10%	low	low
Generation Thermocoupler	10%	(5% - 8%)	low	low
Rankine Cycle	42%	40%	med	med
Single Reheat Rankine	46%	44%	med-high	med-high
Double Reheat Rankine	48%	46%	high	high
Regeneration Rankine (open)	45%	43%	high	med-high
Regen. Rankine (closed)	47%	44%	high	high
Steam Turbine Cogeneration	100%	80%	high	high

Heat Energy (degraded) → Electrical Energy (noble)



Engine Testing – Cogeneration




Figure 2. Cogeneration (Condensing) Cycle





Indiana Trip



■ Key Takeaways:

- Cummins has already implemented closed cell foam insulation in the roof.
- Absorption chillers can potentially be combined with the exhaust gases as the energy source.
- The exhaust gases (post analysis) are being neglected as a potential energy source.

Cummins wants us to focus resources on designing a system for the exhaust gases along with our other design analyses.




Additional Ideas



- Wind Turbine/High Altitude wind turbines
- Heat treat facilities/components
- More efficient Air Conditioning Units/HVAC
- Making the building more green
 - Check 179D federal tax reduction
 - What are some Go Green building regulations






Summary



Major energy users identified, costs estimated for the current facility use.

In addition to the main areas of improvement, several other ideas will be pursued in the following semester.



Conceptualized ideas have been estimated in terms of energy use and cost.

Primary focus for implementing changes at the facility will be harnessing the exhaust gases from the facility.





References

1. “Electric Power Monthly with Date for August 2014” *Independent Statistics & Analysis; U.S Energy Information Administration*. Web. 24 Oct 2014.
<http://www.eia.gov/electricity/monthly/pdf/epm.pdf>
2. Murugavel, V., and R. Saravanan. "LIFE CYCLE COST ANALYSIS OF WASTE HEAT OPERATED ABSORPTION COOLING SYSTEMS FOR BUILDING HVAC APPLICATIONS." *Department of Mechanical Engineering, Anna University* (2010): 1-9.
http://www.eia.gov/electricity/monthly/epm_table_grapher.cfm?t=epmt_5_6_a
3. “Dynamometer Review.” *Engineers EDGE*. Web. 17 Oct 2014.
<http://www.engineersedge.com/industrial-equipment/dynamometer-review.htm>
4. “Insulation. – Department of Energy” Web. 30 October 2014.
<http://energy.gov/energysaver/articles/insulation>
<http://energy.gov/energysaver/articles/insulation-materials>





Questions?